



NOTES:

- 1- DURING INITIAL SEWER INSTALLATION CLEANOUT SHALL EXTEND AS SHOWN. AFTER HOME CONSTRUCTION CLEANOUT SHALL BE ADJUSTED TO GRADE.
- 2- BACKFILL AND COMPACTION REQUIREMENTS SHALL CONFORM TO CITY STANDARD SPECIFICATIONS.
- 3- 4" DIAMETER-2% MINIMUM.
6" DIAMETER- 1% MINIMUM.
- 4- CLEANOUT DIAMETER TO BE SAME SIZE AS LATERAL.
- 5- BRASS PLUG MARKED WITH "S" PLACED IN TOP OF CURB MAY BE USED IN LIEU OF INSCRIBED "S" IN FACE.
- 6- PIPE LAID WITH BELL OR COLLAR ENDS UP-GRADE.

CITY OF ST. GEORGE ENGINEERING DEPARTMENT

**P.V.C. SERVICE CONNECTION
NEW P.V.C. SEWER MAINS**

REVISIONS		
DATE	DESCRIPTION	BY
8-2004	REVISED ELBO	LBB

STANDARD DWG. NO.	
232	1 OF 1
APPROVED: <i>[Signature]</i>	
DATE: 9/04	BY: LBB