





LEGEND

-  SAND UNDERFILL (SEE NOTE (2))
-  SAND OR SPOIL (SEE NOTE (2))
-  SPOIL OR SAND (SEE NOTE (2))

NOTES:

1. SEE CONDUIT INSTALLATION 111.A. TABLE 2 FOR CONDUIT BURIAL DEPTH REQUIREMENTS.
2. SEE CONDUIT INSTALLATION 111.B. FOR REQUIREMENTS APPLICABLE TO BACKFILL MATERIAL.
3. WARNING TAPE WILL BE PROVIDED ABOVE CONDUIT ZONE APPROXIMATELY 6" TO 1 FT. BELOW GRADE.
4. CONDUITS SHALL BE SPACED 3" EDGE-TO-EDGE.
5. IF MORE THAN ONE LAYER IS INSTALLED A 6" SEPARATION WILL BE REQUIRED. ALSO, THE DEPTHS WILL BE MEASURED TO TOP LAYER.
6. SCHEDULE 40 PVC CAN BE SUBSTITUTED WITH HDPE CONTINUOUS CONDUIT WITH ENERGY SERVICES ENGINEER APPROVAL.

<table border="1"> <thead> <tr> <th colspan="3">REVISIONS</th> </tr> <tr> <th>DATE</th> <th>DESCRIPTION</th> <th>BY</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>			REVISIONS			DATE	DESCRIPTION	BY							 <p>CITY OF ST. GEORGE ENERGY SERVICES DEPARTMENT UNDERGROUND STANDARDS</p>	<p>CONDUIT INSTALLATION SINGLE CONDUIT</p>	<p>DETAIL</p>
REVISIONS																	
DATE	DESCRIPTION	BY															
<p>APPROVED: D.J., R.M.</p>		<p>D13</p>															
<p>DATE: 10/01/05 BY: J.S.</p>																	