



LEGEND: _____



PAD MOUNTED SWITCH



4-WAY VAULT



TRANSFORMER



SECONDARY BOX

NOTES:

1. CONTRACTORS TO STENCIL PAINT T-NUMBERS AND TAGS ON OUTSIDE OF TRANSFORMERS, SWITCHES AND PRIMARY JUNCTIONS (NUMBERS TO BE PROVIDED BY CITY)

REVISIONS		
DATE	DESCRIPTION	BY



CITY OF ST. GEORGE
ENERGY SERVICES DEPARTMENT
UNDERGROUND STANDARDS

TAGGING SYSTEM	
APPROVED: D.J., R.M.	
DATE: 10/01/05	BY: J.S.

DETAIL
D19