

Utah State Amendment to International Fuel Gas Code

R156-56-709. Statewide Amendments to the IFGC

- (1) The following paragraph is added at the end of Section 305.1

305.1 General. After natural gas, space and water heating appliances have been adjusted for altitude and the Btu content of the natural gas, the installer shall apply a sticker in a visible location indicating that the proper adjustments to such appliances have been made. The adjustments for altitude and the Btu content of the natural gas shall be done in accordance with the manufacturer's installation instructions and the gas utility's approved practices.

- (2) Chapter 4, Section 401 General, a new section 401.9 is added as follows:

401.9 Meter protection. Gas meters shall be protected from physical damage, including falling ice and snow.

APPLIANCE ADJUSTMENT VERIFICATION

Proper adjustments for altitude and natural gas Btu content have been made to this appliance in accordance with the manufacturer's installation instructions and the gas utility practices.

Building Permit Number: _____

Technician Name: _____

Company: _____

Date: _____

A "Green Sticker" (Appliance Adjustment Verification) will be REQUIRED by the Rough Mechanical Inspection effective January 1, 2006.